

4

3

2

1

REVISION HISTORY

REV	DESCRIPTION	DATE	APPROVED
1	RIB SPACING	9/30/2010	JMC
2	DRAWING REVISION	3/4/2014	MPS

PARTS LIST

ITEM	QTY	PART NUMBER	DESCRIPTION
1	1	C-COLLAR-30IN	30"D COLLAR
2	1	C-LID-30IN-STD	30"D STANDARD LID
3	20	C-RIB	STRUCTURAL RIB
4	1	C-SEAM-10FT	SEAM
5	2	LIFT LUG-PLATE	LIFT LUG
6	1	CONNECTION-4IN-STUB PIPE	4"D STUB PIPE-INLET

11mm x 350mm FRP bond on Outside

SECTIONAL JOINT DETAIL A
SCALE 1/15

Anchor Location

Item	(")	C	Item	(")
Cylinder Thickness	0.400"		Liquid Depth (holding tank)	110"
End Cap Thickness	0.94"		Septic Chamber Depth	N/A
Inlet Height (C.L.)	112"		Effluent Chamber Depth	N/A
Outlet Height (C.L.)	N/A		Chamber Wall Dimensions	N/A
Inlet Diameter	4"		Height:	N/A
Outlet Diameter	N/A		Thickness:	N/A
Rib Dimension (C to C)	16.5"		Opening Diameter:	N/A

DRAWN
marks
CHECKED

3/11/2014

MFG

APPROVED

WEIGHT

LENGTH

2,631 kg (5,800 lbs)

31' 1"

WORKING CAPACITY

62,910L (13,838 IG, 16,606 USG)

OVERALL CAPACITY

65,410L (14,388 IG, 17,266 USG)

TITLE

BX14000S UNDERGROUND FIBREGLASS
SEWAGE HOLDING TANK

SIZE

C

SCALE

DWG NO

BX14000S-02

7' Burial Depth

REV

2

SHEET 1 OF 2

4

3

2

1