

4

3

2

1

REVISION HISTORY

REV	DESCRIPTION	DATE	APPROVED
1	RIB SPACING	9/30/2010	JMC
2	DRAWING REVISION	3/5/2014	MPS

PARTS LIST

ITEM	QTY	PART NUMBER	DESCRIPTION
1	1	C-COLLAR-30IN	30"D COLLAR
2	1	C-LID-30IN-STD	30"D STANDARD LID
3	22	C-RIB	STRUCTURAL RIB
4	1	C-SEAM-10FT	SEAM
5	5	LIFT LUG-PLATE	LIFT LUG
6	1	CONNECTION-4IN-STUB PIPE	4"D STUB PIPE-INLET

11mm x 350mm FRP bond on Outside

SECTIONAL JOINT DETAIL A
SCALE 1/20

Anchor Location

Item	(")	C	Item	(")
Cylinder Thickness	0.400"		Liquid Depth (holding tank)	110"
End Cap Thickness	0.94"		Septic Chamber Depth	N/A
Inlet Height (C.L.)	112"		Effluent Chamber Depth	N/A
Outlet Height (C.L.)	N/A		Chamber Wall Dimensions	N/A
Inlet Diameter	4"		Height:	N/A
Outlet Diameter	N/A		Thickness:	N/A
Rib Dimension (C to C)	16.5"		Opening Diameter:	N/A

DRAWN
MPS
3/5/2014

CHECKED

MFG

APPROVED

WEIGHT
2,880 kg (6,350 lbs)LENGTH
35' 5"WORKING CAPACITY
72,154L (15,872 IG, 19,046 USG)OVERALL CAPACITY
75,044L (16,508 IG, 19,810 USG)

TITLE
BX16000S UNDERGROUND FIBREGLASS
SEWAGE HOLDING TANK

SIZE
C

DWG NO

BX16000S-02

REV
2

SCALE

7' Burial Depth

SHEET 1 OF 2

4

3

2

1