

4

3

2

1

REVISION HISTORY

REV	DESCRIPTION	DATE	APPROVED
1	RIB SPACING	9/30/2010	JMC
2	DRAWING REVISION	3/5/2014	MPS

PARTS LIST

ITEM	QTY	PART NUMBER	DESCRIPTION
1	1	C-COLLAR-30IN	30"D COLLAR
2	1	C-LID-30IN-STD	30"D STANDARD LID
3	1	C-SEAM-10FT	SEAM
4	4	LIFT LUG-PLATE	LIFT LUG
5	28	C-RIB	STRUCTURAL RIB
6	1	CONNECTION-4IN-STUB PIPE	4"D STUB PIPE-INLET

11mm x 350mm FRP bond on Outside

SSECTIONAL JOINT DETAIL A
SCALE 1/15

Anchor Location

Item	(")	C	Item	(")
Cylinder Thickness	0.425"		Liquid Depth (holding tank)	110"
End Cap Thickness	1.03"		Septic Chamber Depth	N/A
Inlet Height (C.L.)	112"		Effluent Chamber Depth	N/A
Outlet Height (C.L.)	N/A		Chamber Wall Dimensions	N/A
Inlet Diameter	4"		Height:	N/A
Outlet Diameter	N/A		Thickness:	N/A
Rib Dimension (C to C)	16.5"		Opening Diameter:	N/A

DRAWN
MPS
3/11/2014
CHECKED

MFG

APPROVED

WEIGHT
3,674 kg (8,100 lbs)
WORKING CAPACITY
87,710L (19,294 IG, 23,153 USG)
OVERALL CAPACITY
91,158L (20,052 IG, 24,062 USG)LENGTH
42' 2"TITLE
BX20000S DEEP BURY UNDERGROUND
FIBREGLASS SEWAGE HOLDING TANK

SIZE
CDWG NO
BX20000S-DB-02REV
2

SCALE

10' Burial Depth

SHEET 1 OF 2

4

3

2

1