REVISION HISTORY			
REV	DESCRIPTION	DATE	APPROVED
1	RIB SPACING	10/30/2010	JMC
2	DRAWING REVISION	3/11/2014	MPS

PARTS LIST			
ITEM	QTY	PART NUMBER	DESCRIPTION
1	1	C-COLLAR-30IN	30"D COLLAR
2	1	C-LID-30IN-STD	30"D STANDARD LID
3	6	C-RIB-NEW	STRUCTURAL RIB
4	1	C-SEAM-10FT	SEAM
5	1	LIFT LUG-PLATE	LIFT LUG
6	1	CONNECTION-4IN-STUB PIPE	4"D STUB PIPE-INLET







6mm x 200mm min. FRP bond on Outside

SECTIONAL JOINT DETAIL A
SCALE 1/15



Item	(")	C	Item	(")
Cylinder Thickness	0.425"		Liquid Depth (holding tank)	110"
End Cap Thickness	1.03"		Septic Chamber Depth	N/A
Inlet Height (C.L.)	112"		Effluent Chamber Depth	N/A
Outlet Height (C.L.)	N/A		Chamber Wall Dimensions	N/A
Inlet Diameter	4"		Height:	N/A
Outlet Diameter	N/A		Thickness:	N/A
Rib Dimension (C to C)	16.5"		Opening Diameter:	N/A

DRAWN	MPS	7/19/2022	
CHECKED			
MFG			
APPROVED			
WEIGHT	1,588 kg (3,500 lbs)	LENGTH	13' 11"
WORKING CAPACITY	26,362L (5,799 IG, 6,959 USG)		
OVERALL CAPACITY	27,239L (5,992 IG, 7,190 USG)		

TITLE
BX6000S DEEP BURIAL UNDERGROUND FIBREGLASS SEWAGE HOLDING TANK

SIZE	DWG NO	REV
C	BX6000S-DB-02	2

SCALE 10' Burial Depth

SHEET 1 OF 1